

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0992:116 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Napco, 333 Bayview Ave., Amityville NY 11701
Contact: *Edmund Gregorian (631) 842-9400 Fax (631) 842-2726

DESIGN: Models MA3000 and S5500 (SIGNATURE 5500). Local, central station (protected premises); automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

MA3000/S5500	Control Unit
RB3008/RM3008	Relay Board/Relay Module
PS3000	Power Supply
CF5530	Supervisory Board
CB1518KIT	Tamper Kit
RBATH1	Wiring Harness
H247/H1578/CF1518	Enclosure
RP3000LCD/CF300LCD ⁽¹⁾	Keypads
EZM3004/EZM3008 ⁽¹⁾	Zone Expansion Module
CC5502LCD/CF5500LCD ⁽²⁾	Keypads
ZEMM5504/ZEMM5508 ⁽²⁾	Zone Expansion Module
TRF-14/-15	Transformer
EOL2.2K/130	End of Line Resistor

⁽¹⁾ : For use with Model MA3000

⁽²⁾ : For use with Model S5500

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Burglary and other non-fire functions were not examined. Refer to listee's data sheet for compatible non-fire devices.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager